

January 11, 2007

Mr. Alan Bergren  
Town Manager  
Town of East Hampton  
20 East High Street  
East Hampton, CT 06424

Re: Hazardous Materials Survey  
13 Watrous and 103 Main Street  
East Hampton, CT

Dear Mr. Bergren:

Tighe & Bond performed an asbestos, lead paint and hazardous materials evaluation at the above referenced properties on August 8, 9 and 10, 2005. Scott M. Mossey, who is a Connecticut licensed Asbestos Inspector (#000371) and Project Designer (#000237), conducted the survey effort.

Prior to any renovation or demolition, a survey is needed to identify and quantify asbestos, lead and other hazardous materials of environmental or regulatory concern. The survey is required by the state of Connecticut's Standard for Asbestos Abatement Section 19a-332a; Environmental Protection Agency's (EPA's) National Emissions Standards for Hazardous Air Pollutants (NESHAPS) regulations; and applicable portions of the Occupational Safety and Health Administration (OSHA) 29 CFR 1926.1101 (asbestos) and 29 CFR 1926.62 (lead) construction regulations.

The purpose of this inspection was to assist the Town of East Hampton in identifying asbestos, lead based paint and other hazardous materials at two sites.

#### **Asbestos Survey**

Scott M. Mossey, who is a Connecticut, licensed Asbestos Inspector (#000371), collected all asbestos bulk samples. All samples were labeled and collected in appropriate sample containers and submitted to Thad King Director of Health, Chatham Health District. Mr. King, in turn, submitted the samples to the State of Connecticut Department of Public Health (CDPH) Laboratory Services located at 10 Clinton Street, Hartford, CT for analyses in accordance with Environmental Protection Agency (EPA) Method 600/R-93/116.

A summary of the asbestos bulk sampling data and the laboratory results is included in Tables 1 and 2 for 13 Watrous and 103 Main Street respectively. The sampling methods generally followed those outlined in the Asbestos Hazard Emergency Response Act (AHERA) regulations.

The laboratory data presented in the Appendix A provides additional information on the sample analyses.

The EPA defines Asbestos Containing Material (ACM) as those that have greater than 1% asbestos. The results from the analyses indicate that several materials are considered ACM. Refer to Table 1 for detailed asbestos laboratory results. Assumed materials are also listed in Appendix A and consist of material that could not be tested due to structural integrity of the facility. These include such items as roof shingles roof flashing, foundation and exterior damproofing, gasketing, and valve packings. Refer to Table 1 of this document for location, sample numbers, and comments on a per material basis.

### **Hazardous Materials Components**

Tighe & Bond performed a visual inspection of building equipment and materials that have the potential to contain hazardous components and have potential for environmental impacts due to improper storage or disposal.

These materials typically consist of polychlorinated bi-phenyls (PCBs), mercury switches and lighting, oils, paints, thinners, cleaning chemicals, etc. These materials generally fall under universal waste protocol and must be collected and disposed/recycled in accordance with applicable regulations. Other potentially impacted items include smoke detectors, various electrical pumps and motors that are also subject to universal waste disposal regulations.

Refer to Table 3 of this document for quantities and location of comments on a per material basis.

### **Lead Based Paint**

An investigation for the presence of painted surfaces was also performed. Fourteen different paint applications identified may have the potential to be impacted and rendered airborne during renovation activities. Refer to Table 4 of this document for quantities and location of comments on a per material basis.

Lead paint samples were collected from the referenced areas and were submitted to the CTDPH Laboratory Services for subsequent analyses in accordance with the State of Connecticut 7082 method. The laboratory data is presented in Appendix B. The Consumer Safety Product Council defines lead containing paint as those sampled that have greater than 0.50% lead by weight in the dried paint mixture. The test results show that two of the 14 samples have levels of lead that exceeds the 0.50% lead by weight level.

- White paint on steel beams located at 13 Watrous (Bldg # 1)
- Red paint on exterior stairwell at 13 watrous ( Bldg # 2)

In general, all renovation contractors must comply with the OSHA CFR 1926.62 Lead in Construction Regulations when impacting a painted surface that has not been subject to testing

for lead concentrations. Activities that have potential for exposure to significant airborne levels of lead include torch cutting, abrasive mechanical saw cutting, dry sanding, and abrading of painted surfaces. If these or other abrasive methods are intended for use on other painted or untested surfaces during the renovation, then worker protection, work area containment, exposure monitoring, and strict adherence to the OSHA Lead in Construction Regulations shall apply.

The disposal of painted metal components is exempt from special lead containing or lead contaminated disposal requirements so long as the paint remains intact to its substrate and the metal is subject to recycling.

### **Conclusion**

Tighe & Bond has confirmed the presence of ACM and hazardous materials that have potential for environmental impact depending on future building uses and or renovation/demolition activities. If renovation or demolition to any part of the property is planned, Tighe & Bond recommends a more thorough, intrusive type of asbestos inspection to include concealed locations and the confirmation of asbestos content in assumed ACM's having potential for disturbance. At the current time, if no renovations or demolition are planned the materials listed as asbestos containing and having toxic levels of lead paint pose no immediate threat to public or current occupants of the properties.

Very truly yours,

TIGHE & BOND, INC.

Scott Mossey  
Environmental Scientist

James T. Olsen, LEP  
Senior Hydrogeologist/Office Manager

cc: Dave Terry – East Hampton Brownsfield Steering Committee

**Table 1**  
**ASBESTOS INVENTORY**  
**13 Watrous Street**  
**East Hampton, CT**

Sample #	Material	Location	Quantity	Result	Comment
01A,B,C	Sheetrock	01A- 1st fl office. 01B Shop Office. 01C 2nd floor office/bathroom. 2nd floor building # 2 (two)		-	Front office, bathroom 1st floor, shop office, 2nd floor office /bathroom Building # 1. Note Debris throughout all locations of building were sheetrock present. Aprox 1 cubic yard of debris. Building # 2 at 2nd floor aprox 50 SF and 1 cubic yard debris.
02A,B,C	Joint Compound/tape	01A 1st fl office. 01B Shop Office. 01C 2nd floor office/bathroom. 2nd floor building # 2 (two)		-	Front office, bathroom 1st floor, shop office, 2nd floor office /bathroom Building # 1. Note Debris throughout all locations of building were sheetrock present. Aprox 1 cubic yard of debris. Building # 2 at 2nd floor aprox 50 SF and 1 cubic yard debris.
03A,B,C	White/Gray floor levelastic	1st floor front office, building # 1		-	1st floor front office. Poor condition broken cracked, adhered to concrete sub floor. Building # 1
04A,B,C	White textured ceiling paint type I	1st floor bathroom		-	1st floor front office. Poor condition broken cracked, adhered to concrete sub floor. Building # 1
05A,B,C	Brown/tan wall Panel Mastic	1st floor bathroom		-	1st floor front office. Poor condition broken cracked, adhered to concrete sub floor. Building # 1
06A,B,C	White/gray floor tile	1st floor bathroom		-	1st floor front office. Poor condition broken cracked, adhered to concrete sub floor. Building # 1
07A,B,C	Beige mastic assoc w/ 06A,B,C	1st floor bathroom		-	Mens/womens bathroom 1st floor office area, various stored items in bathroom not accessible. Poor condition broken and loose. Building # 1
08A,B,C	White cloth wrap on fiberglass insulation	Main shop area building# 1, shop area building # 2		-	All lines fiberglass poor condition delaminating of pipe wrapping, no mudded elbows observed.
09A,B,C	Interior window glazing	Throughout all buildings( 1-2-3)		-	Some interior windows covered with plywood or blocked in. All exterior windows blocked in with concrete cinder blocks.
10A,B,C	Black mastic remnant	Main shop area building # 1.		-	Small area located on south east wall.
11 A,B,C	White textured ceiling paint, Type II	Shop Office building # 1		-	Access limited stored materials tires/rims. Some loose debris observed on floor/, previous ceiling demo.
12A,B,C	12" X 12" vinyl self adhesive floor tile.	Shop Office building # 1		-	Access limited stored materials tires/rims. Material in poor condition loose cracked, does not go under wall system.

**Table 1  
ASBESTOS INVENTORY  
13 Watrous Street  
East Hampton, CT**

Sample #	Material	Location	Quantity	Result	Comment
13A,B,C	Vinyl sheet linoleum	2nd floor stair landing, building # 1		-	
14A,B,C	White textured ceiling paint Type III	2nd floor office/bathroom building # 1		-	debris observed throughout 2nd floor previous demo activity. Aprox 1.5 Cubic yards of sheetrock debris
15A,B,C	Tan carpet mastic	2nd floor office/bathroom building # 1		-	debris observed throughout 2nd floor previous demo activity. Aprox 1.5 Cubic yards of debris
16A,B,C	Vinyl sheet linoleum	2nd floor Bathroom		-	debris observed throughout 2nd floor previous demo activity. Aprox 1.5 Cubic yards of debris
17A,B,C	Blower Interface Gasket	Bldg # 3 North East Corner	1sf	+	Material is adhered to boiler at blower unit.
18A,B,C	Interior door caulking	Bldg # 2 entrance door		-	
19A,B,C	Transite Arc protectors	Bldg # 2 sprinkler room		-	Material located in old electrical panel (not in use). Different types of switches and wiring still attached.
20A,B,C	White cloth wiring	Bldg # 2 sprinkler room		-	Material located in old electrical panel (not in use). Different types of switches and wiring still attached.
21A,B,C	Transite Arc board (Black/Gray)	Bldg # 2 sprinkler room	15sf	+	Material located in old electrical panel (not in use). Different types of switches and wiring still attached.
22A,B,C	Asphalt roof shingles (top layer)	Bldg # 2 2nd floor			Exterior overhang at 2nd floor.
23A,B,C	Asphalt roof shingles (2nd layer)	Bldg # 2 2nd floor			Exterior overhang at 2nd floor.
24A,B,C	Sheet linoleum flooring	Bldg # 2 2nd floor			Material attached to plywood sub floor.
25A,B,C	Black floor vapor barrier	Bldg # 2 2nd floor			Material underneath plywood sub floor. Note north east section of floor is unstable/unsafe
26A,B,C	Black tar/Road saver	Bldg # 2 2nd floor			Material in bags located on 2nd floor.

**Table 1**  
**ASBESTOS INVENTORY**  
**13 Watrous Street**  
**East Hampton, CT**

Sample #	Material	Location	Quantity	Result	Comment
27A,B,C	Exterior door caulking	Bldg # 2 2nd floor entrance			
AP	Exterior Roof field/Roof flashing, parapet wall tar and sealants.	Building #1, #2 and #3	Unknown	+	Material not sampled due to repairs made to roof. Current occupation of spaces and potential for water damage. Prior to any renovation or demolition of these materials additional testing is recommended or dispose as asbestos containing material.
AP	All flange gaskets, valve packings located throughout all buildings.	Building #1, #2 and #3	45 ea	+	Material not sampled due to inaccessibility, gaskets valve packings observed on sprinkler systems, former heating piping, domestic water lines. Assume material asbestos containing, or additional testing required prior to disposal.
AP	All steel fire doors	Building #1, #2 and #3	10 ea	+	Material not sampled due to inaccessibility. Assume material asbestos containing, or additional testing required prior to disposal.

**LEGEND**

AP = ASSUMED POSITIVE

CT = QUANTITY

LF = LINEAR FOOT

SF= SQUARE FOOT

" - " NEGATIVE FOR ASBESTOS CONTENT

" + " POSITIVE FOR ASBESTOS CONTENT

SHADED AREAS INDICATE A POSITIVE RESULT

**Table 2  
ASBESTOS  
INVENTORY  
103 Main Street  
East Hampton, CT**

Sample #	Material	Location	Quantity	Result	Comment
01A,B,C	Sheetrock ceiling	103 Main Street	120 SF	+	Former boiler room, debris throughout area, poor condition, water damage. Attached to wooden 2" X 6" joist.
02A,B,C	Boiler interface gaskets.	103 Main Street	2 SF	+	Oil fired forced hot air furnace with blower unit. No interior insulation observed in unit.
03A,B,C	Cloth wiring	103 Main Street		-	Cloth wrap wiring good condition. Conduit metal 3/4 " wall mounted, not internal wiring.
04A,B,C	Roofing	103 Main Street, south west side of building		-	Exterior roofing debris unknown origin.
05A,B,C	Roofing	103 Main Street, west side of building		-	Exterior roofing debris unknown origin.
06A,B,C	Roofing	103 Main Street, north side of building		-	Exterior roofing debris unknown origin.

**LEGEND**

AP = ASSUMED POSITIVE

CT = QUANTITY

CY = CUBIC YARD

LF = LINEAR FOOT

SF = SQUARE FOOT

" - " NEGATIVE FOR ASBESTOS CONTENT

" + " POSITIVE FOR ASBESTOS CONTENT

SHADED AREAS INDICATE A POSITIVE RESULT

**Table 3**  
**HAZARDOUS MATERIALS INVENTORY**  
**13 Watrous Street**  
**East Hampton, CT**

Location - 13 Watrous	Contents	Quantity	Hazardous Constituents
Building # 1 throughout	Brake cleaner/WD-40	20 EA	3
Building # 1 throughout	Various types spray paint	25 EA	3
Building # 1 throughout	Antifreeze (new/used)	10 - 1 gallon	3
Building #1	Industrial parts cleaner	30 gallons	3
Building # 1 throughout	Brake fluid	15 EA	1
Building # 1 throughout	Loose/used oil 1 quart	25 EA	1
Building # 1 throughout	Loose/used oil bins	3 - 5 gallon	1
Building #1	Loose/used oil in old 275 gallon tank	75 - 100 gallons	1
Building # 1 throughout	Gasoline containers( various sizes)	15 EA	1
Building # 1 throughout	Loose new/used car batteries	15 EA	3
Building #1/under shop office floor	Well surface jet pump motor	1 EA	2,3
Building #1	ZEP power wash solution	2 - 5 gallon	5
Building #1 west side (above doors)	Power transformer	1 EA	2
Building #1	Mercury thermometer	2 EA	3
Building #1	Heater blower motor	1 EA	2
Building #1	Transmission fluids in stored cars	UNKNOWN	1
Building #1	Engine oil in stored cars	UNKNOWN	1
Building #1	Gasoline stored cars	UNKNOWN	1
Building #1	Diesel oils in stored motors/equipment	UNKNOWN	1
Building #1	Antifreeze in stored cars	UNKNOWN	3
Building #1	Abrasive blasting quartz	4 - 50lbs bags	6
Building #1	Fluorescent Bulbs	30 - 6ft	3
Building #1	Fluorescent light ballast	15EA	2
Building #1	Old Fluorescent light ballast only	5 EA	2
Building # 2	Fluorescent Bulbs	4 - 4ft	3
Building # 2	Fluorescent Bulbs	2 - 6ft	3
Building # 2 (sprinkler room)	Fluorescent Bulbs	2 - 8ft	3
Building # 2 (throughout)	Fluorescent light ballast	6 EA	2
Building # 2	Compressors W/electrical motors	2 EA	2
Building # 2	Mercury vapor light	1 EA	3
Building # 2	Sprinkler pump motors w/ back-up	2 EA	1,2
Building # 2	Control panel W/ transformer	1 EA	2
Building # 2	Globrite (phosphoric acid)	1 - 66 KG drum	3
Building # 2	Antifreeze	4 - 1 gallon	3
Building # 2	Liquid household bleach	1 - 1/2 gallon	3
Building # 2	Loose stored oil bins	15 gallons	1
Building # 2	Paint stripper	1 gallon	1,3
Building # 2	Brake cleaner/WD-40	2 - cans	1
Building # 2	Microwave oven	1 EA	2,3
Building # 2	Old stored refrigerator (CFC)	1 EA	4
Building # 2 second floor	Fluorescent Bulbs only	3 EA	3
Building # 2 second floor	Loose stored (unknown liquids)	3 - 5 gallons	5
Building # 3	Heater blower motor	1 EA	2
Building # 3	Mercury switches	2 EA	3

**Hazardous Legend Key**

- 1 - Petroleum Products (Gasoline and oils)
- 2 - PCBs (lighting ballast, motor capacitors, transformers)
- 3 - Hazardous or Regulated Materials (Batteries, antifreeze, paints, solvents, mercury switches and fixtures)
- 4 - CFCs (air conditioners, refrigerators)
- 5 - Unknown constituents
- 6- Other

**Table 3**  
**HAZARDOUS MATERIALS INVENTORY**  
**13 Watrous Street**  
**East Hampton, CT**

Location - 13 Watrous Street (Cont.)	Contents	Quantity	Hazardous Constituents
Building # 3	Old stored refrigerator (CFC)	1 EA	4
Building # 3	Loose stored (unknown liquid red)	5 gallons	5
Building # 3	Loose stored motor oil	6 gallons	1
Building # 3	Gasoline (containers unknown)	3 - 1.5 gallons	1
Building # 3	Furnace blower motor	1 EA	2

103 Main Street	Contents	Quantity	Hazardous Constituents
Hazardous Materials Inventory	Mercury switches, bulbs	3 EA 2 switches located on boiler unit, 1 unit on north wall	3

**Hazardous Legend Key**

- 1 - Petroleum Products (Gasoline and oils)
- 2 - PCBs (lighting ballast, motor capacitors, transformers)
- 3 - Hazardous or Regulated Materials (Batteries, antifreeze, paints, solvents, mercury switches and fixtures)
- 4 - CFCs (air conditioners, refrigerators)
- 5 - Unknown constituents
- 6- Other

**Table 4**  
**LEAD PAINT INVENTORY**  
**13 Watrous Street**  
**East Hampton, CT**

Sample #	Material Description	Location	Concentration Lead by Weight(%)	Comment/ Condition
01L	White exterior paint	Exterior CMU block and concrete	0.04%	Fair to poor condition some loose and peeling paint
02L	Blue exterior paint	Exterior CMU block and concrete	0.03%	Fair to poor condition some loose and peeling paint
03L	Green/gray exterior paint	Exterior CMU block and concrete	0.04%	Good condition.
04L	Green trim paint	Bldg # 1 interior bathroom 1st floor	0.03%	Good condition.
05L	Red paint	Shop office and door trim Bldg # 1	0.03%	Good condition.
06L	Black ceiling paint	Throughout Bldg #1	0.04%	Paint in poor condition loose and peeling from substrate. Paint observed on floor surfaces.
07L	White paint	Throughout shop floor walls Bldg #1	0.07%	Paint in poor condition loose and peeling from substrate.
08L	Gray paint	Throughout shop floor walls Bldg #1	0.04%	Paint in poor condition loose and peeling from substrate.
09L	White paint	Throughout 2nd floor on plywood surfaces	0.03%	Good condition.
10L	White paint	Steel beams Bldg #1	0.0187	Good condition.some loose and peeling paint observed
11L	Light blue paint	Bathroom 2nd Floor Bldg #1	0.02%	Good condition

**Table 4**  
**LEAD PAINT INVENTORY**  
 13 Watrous Street  
 East Hampton, CT

Sample #	Material Description	Location	Concentration Lead by Weight(%)	Comment/ Condition
12L	White paint	Steel beams, columns and walls Bldg #2	0.12%	Good condition
13L	Black paint	Ceiling and wall 2nd floor Bldg #2	0.02%	Good condition
14L	Red exterior	Exterior stair to 2nd floor Bldg #2	1.49%	Paint in poor condition loose, rusted and peeling from metal substrate.

**LEGEND**

**BDL** - Below detection limit = .01 %

**Toxic levels < .050% volume by weight**

Shaded areas indicate lead levels above toxic reporting limits



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, INFORMATION. Contains data for accession 27027242 and collection/reception dates.

Table with columns: REPORT, FINAL REPORT, COMMENT, NR:

Table with columns: TEST(S), RESULT(S)

Main report body containing test results for NPDES NO: 27027242, 27027243, and 27027244. Includes details on asbestos dispersion stain tests and methods used.

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, INFORMATION, COLLECTED, RECEIVED, REPORTED. Contains accession number 27027242 and collection/reception dates.

Table with columns: REPORT, FINAL REPORT, COMMENT. Contains 'O2C/13 WATROUS' in the COMMENT column.

Main table with columns: TEST(S), RESULT(S). Contains three rows of asbestos test results for samples 27027248, 27027249, and 27027249, detailing methods and visual observations.

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, PAG. Includes accession number 27027242 and account number D06424. Includes a table for COLLECTED, RECEIVED, REPORTED dates.

REPORT: FINAL REPORT COMMENT: 03B/13 WATROUS

Main test results table with columns TEST(S) and RESULT(S). Includes specific methods, descriptions, and results for asbestos testing. Includes a disclaimer at the bottom: 'The results in this report relate only to asbestos samples analyzed by EPA test method...'

\*\*\* CONTINUED \*\*\*





STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, and INFORMATION. Includes data for accession 27027251 and collection dates.

Table with columns: REPORT, FINAL REPORT, COMMENT, and 04A/13 WATROUS

Main table with columns: TEST(S) and RESULT(S). Contains detailed test results for three samples (7027252, 7027253, 7027254) including EPA test methods and asbestos findings.

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, PAG. Includes accession number 27027251 and account number 06424. Includes a table for dates: COLLECTED (08/10/05), RECEIVED (08/17/05), REPORTED (12/15/05).

REPORT: FINAL REPORT COMMENT: 04C/13 WATROUS

Main data table with columns TEST(S) and RESULT(S). Contains four rows of asbestos test results for samples 05A/13, 05B/13, and 05C/13, all showing 'No asbestos seen'.

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, PAG. Includes accession number 27027251 and account number 006424. Includes a table with columns: COLLECTED, RECEIVED, REPORTED.

042NOT SPECIFIED
13 WATROUS ST
NOT SPECIFIED CT

Table with columns: COLLECTED, RECEIVED, REPORTED. Values: 08/10/05 00:00, 08/17/05 10:30, 12/15/05 12:22.

Table with columns: REPORT, FINAL REPORT, COMMENT. Values: FINAL REPORT, 05C/13 WATROUS

Main table with columns: TEST(S), RESULT(S). Contains multiple rows of asbestos test results including descriptions like 'BESTOS DISP STAIN' and 'DESCRIPTION - ABS'.

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, PAC. Values: 27027251, 06424, 0, 4

INFORMATION
042NOT SPECIFIED
13 WATROUS ST
NOT SPECIFIED CT

Table with columns: COLLECTED, RECEIVED, REPORTED. Values: 08/10/05 00:00, 08/17/05 10:30, 12/15/05 12:22

Table with columns: REPORT, FINAL REPORT, COMMENT. Values: 06C/13 WATROUS

Main table with columns: TEST(S), RESULT(S). Contains three rows of test results for asbestos staining, including methods, descriptions, and results like 'NEGATIVE' and 'NONFIBROUS (0%)'.

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, PAG. Values: 27027251, D06424, 0, 5. INFORMATION: 042EAST HAMPTON, 13 WATROUS ST, EAST HAMPTON CT

Table with columns: COLLECTED, RECEIVED, REPORTED. Values: 08/10/05 00:00, 08/17/05 10:30, 12/15/05 12:22

REPORT: FINAL REPORT COMMENT: 07B/13 WATROUS

Main table with columns TEST(S) and RESULT(S). Contains two test entries for asbestos analysis with handwritten signature and date 12/16/05.

The results in this report relate only to asbestos samples analyzed by EPA test method EPA/600/R-93/116 for determination of bulk asbestos in building materials and EPA/600/M4-82-020, 1982 interim method for determination of asbestos. This report shall not be reproduced except in full without the written approval

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health  
Division of Laboratory Services  
10 Clinton St., P.O. Box 1689  
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
THAD KING MPH,RS  
20 E.HIGH ST.  
EAST HAMPTON

CT 06424

TOWN NR: 042

I.D.	ACCESSION NO.	ACCOUNT NO.	AGE	S	PAG
	27027251	D06424	0		6

INFORMATION

042EAST HAMPTON

13 WATROUS ST  
EAST HAMPTON CT

COLLECTED	RECEIVED	REPORTED
08/10/05 00:00	08/17/05 10:30	12/15/05 12:22

REPORT	FINAL REPORT	COMMENT
		07C/13 WATROUS

TEST(S)	RESULT(S)
	of the laboratory. This report cannot be used by the client to claim product endorsement. If inhomogenous samples are encountered, layers are analyzed and reported separately.
	----- ** END OF REPORT **



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, INFORMATION, COLLECTED, RECEIVED, REPORTED. Contains accession number 27027263 and collection dates.

Table with columns: REPORT, FINAL REPORT, COMMENT, 08A/13 WATROUS

Main table with columns: TEST(S), RESULT(S). Contains three rows of asbestos test results for samples 27027263, 27027264, and 27027265, including test methods and visual examination descriptions.

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: ID, ACCESSION NO., ACCOUNT NO., AGE, S, PAC. Includes information for 27027263, 06424, 0, 042EAST HAMPTON, 13 WATROUS ST, EAST HAMPTON CT, and collection/reception/reporting dates.

Table with columns: REPORT, FINAL REPORT, COMMENT, 08C/13 WATROUS

Main test results table with columns: TEST(S), RESULT(S). Contains four rows of asbestos testing results for samples 27027266, 27027267, 27027267, and 27027268, all showing negative results.

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, and PAGE. Includes information for 27027263, 06424, 0, and 3. Location: 042EAST HAMPTON, 13 WATROUS ST, EAST HAMPTON CT. Collection/Reporting dates: 08/10/05, 08/17/05, 01/11/06.

REPORT: FINAL REPORT COMMENT: 09C/13 WATROUS

Main test results table with columns TEST(S) and RESULT(S). Contains three entries for EPA test methods (EPA/600/R-93/116) for samples 10A/13, 11A/13, and 13A/13. Results are consistently negative for asbestos.

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health
Division of Laboratory Services
10 Clinton St., P.O. Box 1689
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT
THAD KING MPH,RS
20 E.HIGH ST.
EAST HAMPTON CT 06424

Table with columns: I.D., ACCESSION NO., ACCOUNT NO., AGE, S, PAC. Includes information for 27027263, 06424, 042EAST HAMPTON, 13 WATROUS ST, EAST HAMPTON CT, and collection/reception/reporting dates.

REPORT: FINAL REPORT COMMENT: 11A/13 WATROUS

Main test results table with columns TEST(S) and RESULT(S). Contains three detailed asbestos test entries for samples 27027271, 27027272, and 27027273, including specific methods and visual examination results.

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health  
Division of Laboratory Services  
10 Clinton St., P.O. Box 1689  
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
THAD KING MPH,RS  
20 E.HIGH ST.  
EAST HAMPTON

CT 06424

TOWN NR: 042

I.D.	ACCESSION NO.	ACCOUNT NO.	AGE	S	PAGE
	27027263	006424	0		5
INFORMATION					
042EAST HAMPTON					
13 WATROUS ST EAST HAMPTON CT					
		COLLECTED	RECEIVED	REPORTED	
		08/10/05 00:00	08/17/05 10:30	01/11/06 11:42	

REPORT	FINAL REPORT	COMMENT
		11C/13 WATROUS

TEST(S)	RESULT(S)
---------	-----------

The results in this report relate only to asbestos samples analyzed by EPA test method EPA/600/R-93/116 for determination of bulk asbestos in building materials and EPA/600/M4-82-020, 1982 interim method for determination of asbestos. This report shall not be reproduced except in full without the written approval of the laboratory. This report cannot be used by the client to claim product endorsement. If inhomogenous samples are encountered, layers are analyzed and reported separately.

*Susan [Signature]*  
1/11/06

\*\* END OF REPORT \*\*

STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID	ACCESSION NO.	ACCOUNT NO.
	27027273	006424 0
INFORMATION		
052EAST HAMPTON		
13 WATROUS ST EAST HAMPTON CT		
COLLECTED	RECEIVED	
08/10/05 00:00	08/17/05 10:30	04 11

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

TOWN NR: 042

FINAL REPORT

COMMENT

12A/13 WATROUS

TEST(S)	RESULT(S)
12A/13 WATROUS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
DISP STAIN	NEGATIVE
PROPERTY:	NONFIBROUS (0%), FLEXIBLE
TEST METHOD:	NO-LAYERED
ANALYSIS - ABS	AREA % BY VISUAL EXAMINATION GRAY/WHITE/BLACK
	No asbestos seen. <1% cellulose. RAN
12B/13 WATROUS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
DISP STAIN	NEGATIVE
PROPERTY:	NONFIBROUS (0%), FLEXIBLE
TEST METHOD:	NO-LAYERED
ANALYSIS - ABS	AREA % BY VISUAL EXAMINATION GRAY/WHITE/BLACK
	No asbestos seen. <1% cellulose. RAN
12C/13 WATROUS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
DISP STAIN	NEGATIVE



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

ID	ACCESSION NO.	ACCOUNT NO.	AGE	SEX
	27027273	D06424	0	
INFORMATION				
042EAST HAMPTON				
13 WATROUS ST EAST HAMPTON CT				
COLLECTED		RECEIVED	REPORTED	
08/10/05 00:00		08/17/05 10:30	04/26/06 11:31	

TOWN NR: 042

REPORT	FINAL REPORT	COMMENT
		12C/13 WATROUS

TEST(S)	RESULT(S)
TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NONFIBROUS (0%), FLEXIBLE NO-LAYERED AREA % BY VISUAL EXAMINATION GRAY/WHITE/BLACK No asbestos seen. <1% cellulose. RAN
27027276 13A/13 WATROUS METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
ASBESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NEGATIVE FIBROUS (2%), THIN, FLEXIBLE YES AREA % BY VISUAL EXAMINATION GRAYISH No asbestos seen. 1% cellulose, 3% fiberglass. RAN
027277 13B/13 WATROUS METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
ASBESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NEGATIVE FIBROUS (10%), THIN, FLEXIBLE YES AREA % BY VISUAL EXAMINATION GRAYISH No asbestos seen. 15% cellulose. RAN
027278 13C/13 WATROUS METHOD	

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

ID	ACCESSION NO	ACCOUNT NO	AGE	S	PA
	27027273	D06424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS ST EAST HAMPTON CT					
COLLECTED		RECEIVED		REPORTED	
08/10/05 00:00		08/17/05 10:30		04/26/06 11:31	

PORT	FINAL REPORT	COMMENT
		13C/13 WATROUS

TEST(S)	RESULT(S)
BESTOS DISP STAIN XTURE: MOGENEITY: ECIFIC METHOD: OR: CRIPTION - ABS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE FIBROUS (10%), THIN, FLEXIBLE YES AREA % BY VISUAL EXAMINATION GRAYISH No asbestos seen. 15% cellulose. RAN
7027279 NR:  THOD	NPDES NO:                      IND: COLLECTOR: MOSSEY, S  EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE FIBROUS (50%), CRUMBLY & PAPERLIKE NO-LAYERED AREA % BY VISUAL EXAMINATION GRAY & BROWN gray: No asbestos seen. 2% cellulose. brown: No asbestos seen. 90% cellulose. RAN
7027280 14B/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE FIBROUS (50%), CRUMBLY & PAPERLIKE
BESTOS DISP STAIN XTURE: MOGENEITY: ECIFIC METHOD: OR: CRIPTION - ABS	NEGATIVE FIBROUS (50%), CRUMBLY & PAPERLIKE

\*\*\* CONTINUED \*\*\*



Department of Public Health  
Division of Laboratory Services  
10 Clinton St., P.O. Box 1689  
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
TELEPHONE: (860) 509-8500

ID.	ACCESSION NO.	ACCOUNT NO.	AGE	\$	P.
	27027273	D06424	0		
INFORMATION					
042EAST HAMPTON					
1 WATROUS ST EAST HAMPTON CT					

CHATHAM HEALTH DISTRICT  
THAD KING MPH,RS  
20 E.HIGH ST.  
EAST HAMPTON

CT 06424

TOWN NR: 042

COLLECTED	RECEIVED	REPORTED
08/10/05 00:00	08/17/05 10:54	04/26/06 11:31

PORT	FINAL REPORT	COMMENT
		14B/13 WATROUS

TEST(S)	RESULT(S)
HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NO-LAYERED AREA % BY VISUAL EXAMINATION GRAY & BROWN gray: No asbestos seen. 2% cellulose. brown: No asbestos seen. 100% cellulose. RAN
027281 14C/13 WATROUS HOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NYLAP ACCREDITATION 1237
ESTOS DISP STAIN NATURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NEGATIVE FIBROUS (50%), CRUMBLY & PAPERLIKE NO-LAYERED AREA % BY VISUAL EXAMINATION GRAY & BROWN gray: No asbestos seen. 2% cellulose. brown: No asbestos seen. 100% cellulose. RAN
027282 15A/13 WATROUS HOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NYLAP ACCREDITATION 1237
ESTOS DISP STAIN NATURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NEGATIVE NONFIBROUS (0%), HARD, CRUMBLY YES AREA % BY VISUAL EXAMINATION GRAYISH No asbestos seen. 1% cellulose. RAN (QC-SMI)
027283 15B/13 WATROUS	

\*\*\* CONTINUED \*\*\*





STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID.	ACCESSION NO.	ACCOUNT NO.	AGE	S	P
	27027273	D06424	0		
INFORMATION					
042EAST HAMPTON					
1 WATROUS ST EAST HAMPTON CT					

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

TOWN NR: 042

COLLECTED	RECEIVED	REPORTED
08/10/05 00:00	08/17/05 10:54	04/26/06 11:31

ORT	FINAL REPORT	COMMENT	15C/13 WATROUS
-----	--------------	---------	----------------

TEST(S)	RESULT(S)
---------	-----------

The results in this report relate only to asbestos samples analyzed by EPA test method EPA/600/R-93/116 for determination of bulk asbestos in building materials and EPA/600/M4-82-020, 1982 interim method for determination of asbestos. This report shall not be reproduced except in full without the written approval of the laboratory. This report cannot be used by the client to claim product endorsement. If inhomogenous samples are encountered, layers are analyzed and reported separately.

*Susan Wheeler*  
 Susan Wheeler  
 4/27/06

\*\*\*\*\*  
 \*\* END OF REPORT \*\*



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

I.D.	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027285	D06424	0		
INFORMATION					
0642 EAST HAMPTON					
1 WATROUS ST EAST HAMPTON CT					
		COLLECTED	RECEIVED	REPORTED	
		08/10/05 00:00	08/17/05 10:54	04/27/06 14:46	

REPORT	FINAL REPORT	COMMENT
		16A/13 WATROUS

TEST(S)	RESULT(S)
7027285 16A/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN XTURE: MOGENEITY: ECIFIC METHOD: LOR: CRIPTION - ABS	NEGATIVE FIBROUS (1%), FLEXIBLE YES AREA % BY VISUAL EXAMINATION GRAY/TAN No asbestos seen. 15% cellulose, 1% fiberglass. RAN
7027286 16B/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN XTURE: MOGENEITY: ECIFIC METHOD: LOR: CRIPTION - ABS	NEGATIVE FIBROUS (1%), FLEXIBLE YES AREA % BY VISUAL EXAMINATION GRAY/TAN No asbestos seen. 15% cellulose, 1% fiberglass. RAN
7027287 16C/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN	NEGATIVE

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

ID	ACCESSION NO	ACCOUNT NO.	AGE	S	PA
	27027285	D06424	0		
INFORMATION					
042EAST HAMPTON					
1 WATROUS ST EAST HAMPTON CT					
		COLLECTED	RECEIVED	REPORTED	
		08/10/05 00:00	08/17/05 10:54	04/27/06 14:46	

TOWN NR: 042

REPORT	FINAL REPORT	COMMENT
		16C/13 WATROUS

TEST(S)	RESULT(S)
TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	FIBROUS (15%), FLEXIBLE YES AREA % BY VISUAL EXAMINATION GRAY/TAN No asbestos seen. 15% cellulose, 1% fiberglass. RAN
27027288 17A/13 WATROUS METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	POSITIVE FIBROUS (50%), THREADLIKE YES AREA % BY VISUAL EXAMINATION GRAY 15-25% chrysotile asbestos. 25% cellulose. RAN
27027289 17B/13 WATROUS METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	POSITIVE FIBROUS (50%), THREADLIKE YES AREA % BY VISUAL EXAMINATION GRAY 20-30% chrysotile asbestos. 25% cellulose. RAN
27027290 17C/13 WATROUS METHOD	

\*\*\* CONTINUED \*\*\*





STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

ID	ACCESSION NO	ACCOUNT NO	AGE	S	PA
	27027291	006424	0		
INFORMATION					
042EAST HAMPTON					
1 WATROUS ST EAST HAMPTON CT					
COLLECTED	RECEIVED	REPORTED			
08/10/05 00:00	08/17/05 10:54	05/02/06 14:32			

FINAL REPORT

COMMENT

18A/13 WATROUS

TEST(S)	RESULT(S)
27291 18A/13 WATROUS ID	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE NONFIBROUS (0%), CRUMBLY YES AREA % BY VISUAL EXAMINATION GRAYISH No asbestos seen. 1% cellulose. RAN
27292 18B/13 WATROUS ID	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE NONFIBROUS (0%), CRUMBLY YES AREA % BY VISUAL EXAMINATION GRAYISH No asbestos seen. <1% cellulose. RAN
27293 18C/13 WATROUS ID	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE

\*\*\* CONTINUED \*\*\*



**STATE OF CONNECTICUT**

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

ID	ACCESSION NO	ACCOUNT NO	AGE	5	PAGE
	27027291	D06424	0		2
INFORMATION					
042EAST HAMPTON					
1 WATROUS ST EAST HAMPTON CT					
		COLLECTED	RECEIVED	REPORTED	
		08/10/05 00:00	08/17/05 10:54	05/02/06 14:32	

REPORT	FINAL REPORT	COMMENT
		18C/13 WATROUS

TEST(S)	RESULT(S)
TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NONFIBROUS (0%), CRUMBLY YES AREA % BY VISUAL EXAMINATION GRAYISH No asbestos seen. <1% cellulose. RAM
7027294 19A/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	POSITIVE FIBROUS (10%), CEMENTITIOUS YES AREA % BY VISUAL EXAMINATION GRAY 10-15% chrysotile asbestos. RAM
7027295 19B/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	POSITIVE FIBROUS (10%), CEMENTITIOUS YES AREA % BY VISUAL EXAMINATION GRAY 10-15% chrysotile asbestos. RAM
7027296 19C/13 WATROUS THOD	



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID	ACCESSION NO.	ACCOUNT NO.	AGE	S
	27027291	D06424	0	
INFORMATION				
042EAST HAMPTON				
1 WATROUS ST EAST HAMPTON CT				
COLLECTED	RECEIVED	REPORTED		
06/10/05 00:00	06/17/05 10:54	05/02/05 14:32		

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON

CT 06424

TOWN NR: 042

PORT	FINAL REPORT	COMMENT
		19C/13 WATROUS

TEST(S)	RESULT(S)
ESTOS DISP STAIN TURE: OGENEITY: CIFIC METHOD: OR: RIPTION - ABS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 POSITIVE FIBROUS (10%), CEMENTITIOUS YES AREA % BY VISUAL EXAMINATION GRAY 10-15% chrysotile asbestos. RAN
27297 20A/13 WATROUS ID	NPDES NO:                      IND: COLLECTOR: MOSSEY, S
ESTOS DISP STAIN TURE: OGENEITY: CIFIC METHOD: RI: RIPTION - ABS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE FIBROUS (100%), THREADLIKE YES AREA % BY VISUAL EXAMINATION GRAY No asbestos seen. 100% cellulose. RAN (GC-SMI)
17298 20B/13 WATROUS ID	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
TOS DISP STAIN RE: ENEITY:	NEGATIVE FIBROUS (100%), THREADLIKE YES

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID	ACCESSION NO.	ACCOUNT NO.	AGE	S.	PA
	27027291	006424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS ST EAST HAMPTON CT					
		COLLECTED	RECEIVED	REPORTED	
		08/10/05 00:00	08/17/05 10:54	05/02/06 14:32	

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

TOWN NR: 042

PORT	FINAL REPORT	COMMENT
		208/13 WATROUS

TEST(S)	RESULT(S)
SPECIFIC METHOD: LOR: DESCRIPTION - ABS	AREA % BY VISUAL EXAMINATION GRAY No asbestos seen. 100% cellulose. RAN
7027299 20C/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: LOR: DESCRIPTION - ABS	NEGATIVE FIBROUS (100%), THREADLIKE YES AREA % BY VISUAL EXAMINATION GRAY No asbestos seen. 100% cellulose. RAN
<p>The results in this report relate only to asbestos samples analyzed by EPA test method EPA/600/R-93/116 for determination of bulk asbestos in building materials and EPA/600/M4-82-020, 1982 interim method for determination of asbestos. This report shall not be reproduced except in full without the written approval of the laboratory. This report cannot be used by</p>	

\*\*\* CONTINUED \*\*\*





STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027300	006424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS ST EAST HAMPTON CT					
COLLECTED		RECEIVED		REPORTED	
08/10/05 00:00		08/17/05 10:54		08/09/06 13:47	

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

TOWN NR: 042

REPORT	FINAL REPORT	COMMENT
		21A/13 WATROUS

TEST(S)	RESULT(S)
7027300 21A/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN XTURE: MOGENEITY: ICIFIC METHOD: OR: CRIPTION - ABS	POSITIVE FIBROUS (20%) TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK 10-20% chrysotile asbestos. 3% cellulose. RAN
7027301 21B/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN XTURE: MOGENEITY: ICIFIC METHOD: OR: CRIPTION - ABS	POSITIVE FIBROUS (20%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK 10-20% chrysotile asbestos. 3% cellulose. RAN
7027302 21C/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN	POSITIVE

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027300	006424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS ST EAST HAMPTON CT					

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

COLLECTED	RECEIVED	REPORTED
08/10/05 00:00	08/17/05 10:54	05/09/06 13:47

TOWN NR: 042

PORT	FINAL REPORT	COMMENT
		21C/13 WATROUS

TEST(S)	RESULT(S)
TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	FIBROUS (20%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK 15-25% chrysotile asbestos. 1% cellulose. RAN
7027303 22A/13 WATROUS METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN	NEGATIVE
TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 10% cellulose & hair. RAN
7027304 22B/13 WATROUS METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN	NEGATIVE
TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 10% cellulose & hair. RAN
7027305 22C/13 WATROUS METHOD	

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

ID	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027300	006424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS ST EAST HAMPTON CT					
COLLECTED	RECEIVED	REPORTED			
08/10/05 00:00	08/17/05 10:54	05/09/06 13:47			

TOWN NR: 042

REPORT	FINAL REPORT	COMMENT
		22C/13 WATROUS

TEST(S)	RESULT(S)
BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 10% cellulose & hair RAN
7027306 23A/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 15% cellulose & hair. RAN
7027307 23B/13 WATROUS THOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK
BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR:	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027300	006424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS ST EAST HAMPTON CT					
COLLECTED		RECEIVED	REPORTED		
08/10/05 00:00		08/17/05 10:54	05/09/06 13:47		

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

TOWN NR: 042

REPORT	COMMENT
FINAL REPORT	23B/13 WATROUS

TEST(S)	RESULT(S)
DESCRIPTION - ABS METHOD	No asbestos seen. 20% cellulose & hair. RAN
7027308 23C/13 WATROUS METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN NATURE: HOMOGENEITY: SPECIFIC METHOD: COLOR:	NEGATIVE FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK
DESCRIPTION - ABS METHOD	No asbestos seen. 15% cellulose & hair. RAN
7027309 24A/13 WATROUS METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN NATURE: HOMOGENEITY: SPECIFIC METHOD: COLOR:	NEGATIVE FIBROUS (60%), HARD & PAPERLIKE NO-LAYERED AREA % BY VISUAL EXAMINATION GRAY & BROWN
DESCRIPTION - ABS METHOD	No asbestos seen. 60% cellulose, 1% synthetic fiber. RAN (QC-SMI)
7027310 24B/13 WATROUS METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237

\*\*\* CONTINUED \*\*\*





STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027300	D06424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS ST EAST HAMPTON CT					

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON

CT 06424

TOWN NR: 042

COLLECTED	RECEIVED	REPORTED
08/10/05 00:00	08/17/05 10:54	05/09/06 13:47

REPORT	FINAL REPORT	COMMENT
		24C/13 WATROUS
TEST(S)	RESULT(S)	

determination of asbestos. This report shall not be reproduced except in full without the written approval of the laboratory. This report cannot be used by the client to claim product endorsement. If inhomogenous samples are encountered, layers are analyzed and reported separately.

*Susan [Signature]*  
 5/10/06

-----  
 \*\* END OF REPORT \*\*



**STATE OF CONNECTICUT**

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID.	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027312	006424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS ST EAST HAMPTON CT					

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

TOWN NR: 042

COLLECTED	RECEIVED	REPORTED
08/10/05 00:00	08/17/05 10:54	05/10/06 13:30

PORT	FINAL REPORT	COMMENT
		25A/13 WATROUS

TEST(S)	RESULT(S)
---------	-----------

027312 25A/13 WATROUS  
HOD

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020  
 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY  
 THE NVLAP ACCREDITATION 1237

ESTOS DISP STAIN  
 TURE:  
 DGENEITY:  
 CIFIC METHOD:  
 OR:  
 CRIPTION - ABS

NEGATIVE  
 FIBROUS (30%), TARLIKE  
 YES  
 AREA % BY VISUAL EXAMINATION  
 BLACK  
 No asbestos seen. 40% cellulose & hair.  
 RAN

027313 25B/13 WATROUS  
HOD

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020  
 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY  
 THE NVLAP ACCREDITATION 1237

ESTOS DISP STAIN  
 TURE:  
 DGENEITY:  
 CIFIC METHOD:  
 OR:  
 CRIPTION - ABS

NEGATIVE  
 FIBROUS (30%), TARLIKE  
 YES  
 AREA % BY VISUAL EXAMINATION  
 BLACK  
 No asbestos seen. 30% cellulose & hair.  
 RAN

027314 25C/13 WATROUS  
HOD

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020  
 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY  
 THE NVLAP ACCREDITATION 1237

ESTOS DISP STAIN

NEGATIVE

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027312	D06424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS ST EAST HAMPTON CT					
COLLECTED		RECEIVED	REPORTED		
08/10/05 00:00		08/17/05 10:54	05/10/06 13:30		

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

TOWN NR: 042

REPORT	FINAL REPORT	COMMENT
		25C/13 WATROUS

TEST(S)	RESULT(S)
TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	FIBROUS (30%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 40% cellulose & hair. RAN
7027315 26A/13 WATROUS METHOD	MPDES NO: IND: COLLECTOR: MOSSEY, S EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
ASBESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NEGATIVE NONFIBROUS (0%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. <1% cellulose. RAN
7027316 26B/13 WATROUS METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
ASBESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NEGATIVE NONFIBROUS (0%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 1% cellulose. RAN
7027317 27A/13 WATROUS	

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID.	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027312	D06424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS EAST HAMPTON CT					

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

COLLECTED	RECEIVED	REPORTED
08/10/05 00:00	08/17/05 10:55	05/10/06 13:30

TOWN NR: 042

PORT	FINAL REPORT	COMMENT
		27A/13 WATROUS

TEST(S)	RESULT(S)
METHOD  BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE NONFIBROUS (OX), CRUMBLY YES AREA % BY VISUAL EXAMINATION GRAYISH <1% chrysotile asbestos, 1% cellulose. RAN
27027318 27B/13 WATROUS METHOD  BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE NONFIBROUS (OX), CRUMBLY YES AREA % BY VISUAL EXAMINATION GRAYISH <1% chrysotile asbestos, 1% cellulose. RAN
27027319 27C/13 WATROUS METHOD  BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD:	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE NONFIBROUS (OX), CRUMBLY YES AREA % BY VISUAL EXAMINATION

\*\*\* CONTINUED \*\*\*



STATE OF CONNECTICUT

Department of Public Health  
Division of Laboratory Services  
10 Clinton St., P.O. Box 1689  
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
THAD KING MPH,RS  
20 E. HIGH ST.  
EAST HAMPTON CT 06424

ID	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027312	006424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS EAST HAMPTON CT					
		COLLECTED	RECEIVED	REPORTED	
		08/10/05 00:00	08/17/05 10:55	05/10/06 13:30	

FINAL REPORT

COMMENT

27C/13 WATROUS

TEST(S)

RESULT(S)

DESCRIPTION - ABS

GRAYISH  
<1% chrysotile asbestos, 1% cellulose.  
RAN (GC-SMI)

The results in this report relate only to asbestos samples analyzed by EPA test method EPA/600/R-93/116 for determination of bulk asbestos in building materials and EPA/600/M4-82-020, 1982 interim method for determination of asbestos. This report shall not be reproduced except in full without the written approval of the laboratory. This report cannot be used by the client to claim product endorsement. If inhomogenous samples are encountered, layers are analyzed and reported separately.

*Susan*  
5/10/06

\*\* END OF REPORT \*\*



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500


CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E. HIGH ST.  
 EAST HAMPTON CT 06424

ID	ACCESSION NO	ACCOUNT NO	AGE	S	F
	27027320	D06424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS EAST HAMPTON CT					
		COLLECTED	RECEIVED	REPORTED	
		08/10/05 00:00	08/17/05 10:55	05/17/05 10:09	

TOWN NR: 042

REPORT	FINAL REPORT	COMMENT
		01A/103 MAIN ST

TEST(S)	RESULT(S)
** 27027320 01A/103 MAIN ST METHOD  ASBESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 POSITIVE FIBROUS (50%), PAPERLIKE YES AREA % BY VISUAL EXAMINATION LT.GRAY 40-60% chrysotile asbestos. RAN
27027321 01B/103 MAIN ST METHOD  ASBESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 POSITIVE FIBROUS (50%), PAPERLIKE YES AREA % BY VISUAL EXAMINATION LT.GRAY 40-60% chrysotile asbestos. RAN
27027322 01C/103 MAIN ST METHOD  ASBESTOS DISP STAIN	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 POSITIVE





**STATE OF CONNECTICUT**

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

ID	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027320	DC6424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS EAST HAMPTON CT					
		COLLECTED	RECEIVED	REPORTED	
		08/10/05 00:00	08/17/05 10:55	05/17/05 10:09	
		TOWN NR: 042			

REPORT	FINAL REPORT	COMMENT
		01C/103 MAIN ST

TEST(S)	RESULT(S)
TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	FIBROUS (50%), PAPERLIKE YES AREA % BY VISUAL EXAMINATION LT.GRAY 40-60% chrysotile asbestos. RAN
27027323 02A/103 MAIN ST METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
ASBESTOS DISP STAIN	POSITIVE
TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	FIBROUS (70%) YES AREA % BY VISUAL EXAMINATION TAN 60-80% chrysotile asbestos. RAN
27027324 02B/103 MAIN ST METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
ASBESTOS DISP STAIN	POSITIVE
TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	FIBROUS (70%) YES AREA % BY VISUAL EXAMINATION TAN 60-80% chrysotile asbestos. RAN
27027325 02C/103 MAIN ST METHOD	



**STATE OF CONNECTICUT**

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

ID	ACCESSION NO	ACCOUNT NO.	AGE	S	P
	27027320	D06424	0		
INFORMATION					
042EAST HAMPTON					
13 WATROUS EAST HAMPTON CT					
COLLECTED	RECEIVED	REPORTED			
08/10/05 00:00	08/17/05 10:55	05/17/05 10:09			

**FINAL REPORT**

COINCIDENT

020/103 MAIN ST

TEST(S)

RESULT(S)

TESTOS DISP STAIN  
 NATURE:  
 HOMOGENEITY:  
 SPECIFIC METHOD:  
 COLOR:  
 DESCRIPTION - ABS

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020  
 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY  
 THE NVLAP ACCREDITATION 1237  
 POSITIVE  
 FIBROUS (70%)  
 YES  
 AREA % BY VISUAL EXAMINATION  
 TAN  
 50-70% chrysotile asbestos.  
 RAN

027326 03A/103 MAIN ST

NPDES NO: IND:  
 COLLECTOR: MOSSEY, S

METHOD

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020  
 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY  
 THE NVLAP ACCREDITATION 1237

TESTOS DISP STAIN  
 NATURE:  
 HOMOGENEITY:  
 SPECIFIC METHOD:  
 COLOR:  
 DESCRIPTION - ABS

NEGATIVE  
 FIBROUS (50%), CYLINDRICAL WIRE WRAP  
 YES  
 AREA % BY VISUAL EXAMINATION  
 BLACK  
 No asbestos seen. 40% cellulose.  
 RAN (QC-BMI)

027327 03B/103 MAIN ST

METHOD

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020  
 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY  
 THE NVLAP ACCREDITATION 1237

TESTOS DISP STAIN  
 NATURE:  
 HOMOGENEITY:

NEGATIVE  
 FIBROUS (50%), CYLINDRICAL WIRE WRAP  
 YES



**STATE OF CONNECTICUT**

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E. HIGH ST.  
 EAST HAMPTON CT 06424

ID.	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027320	D06424	0		
INFORMATION					
042EAST HAMPTON					
103 MANI ST EAST HAMPTON CT					
COLLECTED		RECEIVED	REPORTED		
08/10/05 00:00		08/17/05 11:15	05/17/06 10:09		
TOWN NR: 042					

REPORT	FINAL REPORT	COMMENT
		03B/103 MAIN ST

TEST(S)	RESULT(S)
---------	-----------

**SPECIFIC METHOD:** AREA % BY VISUAL EXAMINATION  
**COLOR:** BLACK  
**DESCRIPTION - ABS:** No asbestos seen. 60% cellulose.  
 RAN

27027328 03C/103 MAIN ST  
 METHOD

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020  
 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY  
 THE NVLAP ACCREDITATION 1237

**ASBESTOS DISP STAIN:** NEGATIVE  
**TEXTURE:** FIBROUS (50%), CYLINDRICAL WIRE WRAP  
**HOMOGENEITY:** YES

**SPECIFIC METHOD:** AREA % BY VISUAL EXAMINATION  
**COLOR:** BLACK  
**DESCRIPTION - ABS:** No asbestos seen. 50% cellulose.  
 RAN

27027329 04A/103 MAIN ST  
 METHOD

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020  
 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY  
 THE NVLAP ACCREDITATION 1237

**ASBESTOS DISP STAIN:** NEGATIVE  
**TEXTURE:** FIBROUS (10%), TARLIKE  
**HOMOGENEITY:** YES

**SPECIFIC METHOD:** AREA % BY VISUAL EXAMINATION  
**COLOR:** BLACK  
**DESCRIPTION - ABS:** No asbestos seen. 15% cellulose & hair.  
 RAN

27027330 04B/103 MAIN ST  
 METHOD

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020



STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

ID.	ACCESSION NO.	ACCOUNT NO.	AGE	S	PA
	27027320	D06424	0		
INFORMATION					
042EAST HAMPTON					
103 MANI ST EAST HAMPTON CT					
		COLLECTED	RECEIVED	REPORTED	
		08/10/05 00:00	08/17/05 11:15	05/17/06 10:09	

FINAL REPORT

COMMENT

04B/103 MAIN ST

TEST(S)	RESULT(S)
BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237 NEGATIVE FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 15% cellulose & hair. RAN
7027331 04C/103 MAIN ST METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NEGATIVE FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 15% cellulose & hair. RAN
7027332 05A/103 MAIN ST METHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237
BESTOS DISP STAIN TEXTURE: HOMOGENEITY: SPECIFIC METHOD: COLOR: DESCRIPTION - ABS	NEGATIVE FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 15% cellulose & hair. RAN
7027333 05B/103 MAIN ST	

\*\*\* CONTINUED \*\*\*



**STATE OF CONNECTICUT**

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

ID	ACCESSION NO	ACCOUNT NO.	AGE	S	PA
	27027320	D06424	0		
INFORMATION					
042EAST HAMPTON					
103 MANI ST EAST HAMPTON CT					
COLLECTED	RECEIVED	REPORTED			
08/10/05 00:00	08/17/05 11:15	05/17/06 10:09			

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

TOWN NR: 042

REPORT	FINAL REPORT	COMMENT
		05B/103 MAIN ST
TEST(S)	RESULT(S)	
ETHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237	
BBESTOS DISP STAIN EXTURE: HOMOGENEITY: ECIFIC METHOD: OLOR: DESCRIPTION - ABS	NEGATIVE FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 15% cellulose & hair. RAN	
27027334 05C/103 MAIN ST ETHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237	
BBESTOS DISP STAIN EXTURE: HOMOGENEITY: ECIFIC METHOD: OLOR: DESCRIPTION - ABS	NEGATIVE FIBROUS (10%), TARLIKE YES AREA % BY VISUAL EXAMINATION BLACK No asbestos seen. 15% cellulose & hair. RAN	
27027335 06A/103 MAIN ST ETHOD	EPA TEST METHOD EPA/600/R-93/116 INTERIM METHOD EPA/600/M4-82-020 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY THE NVLAP ACCREDITATION 1237	
BBESTOS DISP STAIN EXTURE: HOMOGENEITY: ECIFIC METHOD:	NEGATIVE FIBROUS (5%), TARLIKE YES AREA % BY VISUAL EXAMINATION	

\*\*\* CONTINUED \*\*\*

STATE OF CONNECTICUT

Department of Public Health  
 Division of Laboratory Services  
 10 Clinton St., P.O. Box 1689  
 Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
 TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
 THAD KING MPH,RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

ID	ACCESSION NO	ACCOUNT NO.	AGE	S
	27027320	D06424	0	
INFORMATION				
042EAST HAMPTON				
103 MANI ST EAST HAMPTON CT				
COLLECTED	RECEIVED	REP		
08/10/05 00:00	08/17/05 11:15	05/ 10:		

TOWN NR: 042

FINAL REPORT

COMMENT

06A/103 MAIN ST

TEST(S)

RESULT(S)

PTION - ABS

BLACK  
 No asbestos seen. 5% hair.  
 RAN (QC-SMI)

336 06B/103 MANI ST

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020  
 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY  
 THE NVLAP ACCREDITATION 1237

TOS DISP STAIN  
 RE:  
 ENEITY:  
 FIC METHOD:

NEGATIVE  
 FIBROUS (5%), TARLIKE  
 YES  
 AREA % BY VISUAL EXAMINATION  
 BLACK

PTION - ABS

No asbestos seen. 5% hair.  
 RAN

7337 06C/103 MAIN ST

EPA TEST METHOD EPA/600/R-93/116  
 INTERIM METHOD EPA/600/M4-82-020  
 THIS REPORT MAY CONTAIN DATA WHICH IS NOT COVERED BY  
 THE NVLAP ACCREDITATION 1237

TOS DISP STAIN  
 RE:  
 ENEITY:  
 FIC METHOD:

NEGATIVE  
 FIBROUS (5%), TARLIKE  
 YES  
 AREA % BY VISUAL EXAMINATION  
 BLACK

PTION - ABS

No asbestos seen. 3% hair.  
 RAN



STATE OF CONNECTICUT

Department of Public Health  
Division of Laboratory Services  
10 Clinton St., P.O. Box 1689  
Hartford, CT 06144

CONN. CLINICAL TESTING LICENSE # CL-0197  
TELEPHONE: (860) 509-8500

CHATHAM HEALTH DISTRICT  
THAD KING MPH,RS  
20 E.HIGH ST.  
EAST HAMPTON

CT 06424

TOWN NR: 042

ID.	ACCESSION NO.	ACCOUNT NO.	AGE	S	P
	27027320	D06424	0		
INFORMATION					
042EAST HAMPTON					
103 MAIN ST EAST HAMPTON CT					
		COLLECTED	RECEIVED	REPORTED	
		08/10/05 00:00	08/17/05 11:15	05/17/05 10:09	

REPORT	FINAL REPORT	COMMENT	06C/103 MAIN ST
TEST(S)	RESULT(S)		

The results in this report relate only to asbestos samples analyzed by EPA test method EPA/600/R-93/116 for determination of bulk asbestos in building materials and EPA/600/M4-82-020, 1982 interim method for determination of asbestos. This report shall not be reproduced except in full without the written approval of the laboratory. This report cannot be used by the client to claim product endorsement. If inhomogenous samples are encountered, layers are analyzed and reported separately.

*Susan White*  
12/13/06  
----- REPRINT

\*\* END OF REPORT \*\*



STATE OF CONNECTICUT  
 Department of Public Health  
 Division of Laboratory Service  
 10 Clinton St.  
 P.O. Box 1689  
 Hartford, CT 06144  
 CONN. CLINICAL TESTING LICENSE# CL-0197  
 TELEPHONE: (860)509-8500

I.D.	ACCESSION NO.	ACCOUNT NO.	AGE S	PAGE
	22346863	006424	0	1

INFORMATION  
 042EAST HAMPTON  
 13 WATRONS ST  
 EAST HAMPTON CT 06424

CHATHAM HEALTH DISTRICT  
 THAD KING MPH, RS  
 20 E.HIGH ST.  
 EAST HAMPTON CT 06424

COLLECTED	RECEIVED	REPORTED
08/10/05 00:00	08/17/05 09:19	09/16/05 10:36

REPORT	FINAL REPORT	COMMENT	NR:
--------	--------------	---------	-----

TEST(S)	RESULT(S)
---------	-----------

*** 22346863 01L LEAD IN PAINT	NPDES NO: IND: COLLECTOR: SCOTT MOSSEY  0.04 % ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l  <i>Bldg #1 white exterior</i>
22346864 02L LEAD IN PAINT	0.03 % ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l  <i>Bldg #1 Blue exterior</i>
22346865 03L LEAD IN PAINT	0.04 % ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l  <i>Bldgs #2-3 green/gray</i>
22346866 04L LEAD IN PAINT	0.03 % ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l  <i>Bldg #1 green trim Bulbhouse 1<sup>st</sup> fl.</i>
22346867 05L LEAD IN PAINT	0.03 % ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l  <i>Bldg #1 Red shop cabinet door/trim</i>
22346868 06L LEAD IN PAINT	0.04 % ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l  <i>Bldg #1 Black ceiling</i>
22346869 07L LEAD IN PAINT	0.07 % ACCEPTABLE RANGE: 0.0 - 0.50 % PB  <i>Bldg #1 white walls shop floor over</i>



**STATE OF CONNECTICUT**  
 Department of Public Health  
 Division of Laboratory Service  
 10 Clinton St.  
 P.O. Box 1689  
 Hartford, CT 06144  
 CONN. CLINICAL TESTING LICENSE# CL-0197  
 TELEPHONE: (860) 509-8500

I.D.	ACCESSION NO.	ACCOUNT NO.	AGE	S	PAGE
	22346863	D06424	0		2
INFORMATION					
042EAST HAMPTON					
13 WATRONS ST EAST HAMPTON CT 06424					
		<b>COLLECTED</b>	<b>RECEIVED</b>	<b>REPORTED</b>	
		08/10/05 00:00	08/17/05 09:19	09/16/05 10:36	

CHATHAM HEALTH DISTRICT  
 THAD KING MPH, RS  
 20 E. HIGH ST.  
 EAST HAMPTON CT 06424

REPORT	FINAL REPORT	COMMENT	07L
--------	--------------	---------	-----

TEST(S)	RESULT(S)
---------	-----------

22346870 08L LEAD IN PAINT	Method: State of Connecticut 7082 MDL=0.04 mg/l 0.04 % <i>Bldg #1 Gray Shop walls</i> ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l
22346871 09L LEAD IN PAINT	0.03 % <i>Bldg #1 white 2nd fl. on plywood</i> ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l
22346872 10L LEAD IN PAINT	1.87 % <i>Bldg #1 white on steel beams</i> ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l
22346873 11L LEAD IN PAINT	0.02 % <i>Bldg #1 Blue 2nd fl. Bathroom</i> ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l
22346874 12L LEAD IN PAINT	0.12 % <i>Bldg #2+3 white Throughout Beams (I) Columns, walls</i> ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l
22346875 13L LEAD IN PAINT	0.02 % <i>Bldg #2 2nd fl. Balcony</i> ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l
22346876 14L LEAD IN PAINT	1.49 % <i>Ext Stairwell Roof Bldg #2- outside</i> ACCEPTABLE RANGE: 0.0 - 0.50 % PB Method: State of Connecticut 7082 MDL=0.04 mg/l

*[Handwritten Signature]*